

# Sudha Ventilating System Pvt. Ltd.

B-85, M.I.D.C., Ahmadnagar - 414 111.

Tel. No.: 0241-2777285, 6510285.

## Installation Report

Customer: M/S. SIEMENS LTD-MOTORS KALWA THANE BELAPUR ROAD THANE-400601	Invoice No./Date	
	Start Date: 03/05/2007	Finish Date: 15/05/2007
	Quantity Installed	

Contact Person & Telephone No. MR. AMIT GAIKWAD  
09833838504

### Customer Report (Please Tick)

- Installed 306 x Nos. Satisfactorily.
- Balance - nos pending for installation.
- Refused on account of - NA -
- All fixing hardware confirmed. Yes / No  /
- Water Test Carried out.  /
- All Wastege removed from top.  /

### Customer Observation on Performance (Please Tick)

- All units rotating
- ..... Nos. unit not rotating
- Temperature has come down by 3-4°C degrees.
- Smoke going out  Yes /  No
- Any other remark ..  

- AMBIENCE IMPROVED.  
- PROVIDES NATURAL LIGHT.


### Customer Observation on Installation Team.

- |                       |  |   |
|-----------------------|--|---|
| 1. Safety wear used   | <input checked="" type="checkbox"/> / <input type="checkbox"/> | Remark:<br><div style="border: 1px solid black; padding: 5px;"><p>- A TEAM AWARDED BY SIEMENS, CORPORATE HEALTH &amp; SAFETY DEPARTMENT, FOR FOLLOWING GOOD SAFETY PRACTICES.</p></div> |
| 2. Behavior Proper    | <input checked="" type="checkbox"/> / <input type="checkbox"/> |   |
| 3. Working Skill Good | <input checked="" type="checkbox"/> / <input type="checkbox"/> |   |

Signature of Installing Technician

Name:  
Team:

Customer Signature & Stamp

  
Name: MR. KOTWAL.  
Designation: CHIEF MANAGER - PP.  
Date: 20.08.07.